



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: FRTD483

This is a product certificate to certify that

Gulf Trade Link FZCO

Jebel Ali Free Zone Area
PO Box 263127
Dubai, UAE

fire doors manufactured at factory reference B-O:

FireBAN Board 44mm thick FD30

FireBAN Board 54mm thick FD60

FireBAN Board 64mm thick FD90

FireBAN Board 64mm thick FD120

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **FD30, FD60, FD90 and FD120** performance classifications are detailed in the schedule referenced below.



Schedule ref: GTL/S03, GTL/S04

First Issued: 12 October 2010

Revised: 07 January 2015

Reissued 12 October 2015

Valid to: 11 October 2021

Issue No: 8



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +44(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.